

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE <div style="text-align: center;">J</div>		PAGE OF PAGES <div style="text-align: center;">1 7</div>	
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">0004</div>		3. EFFECTIVE DATE <div style="text-align: center;">22-Aug-2002</div>		4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">W16ROE-2156-1458</div>		5. PROJECT NO.(If applicable)	
6. ISSUED BY USA ENGINEER DISTRICT, NEW YORK ATTN: CENAN-CT ROOM 1843 26 FEDERAL PLAZA (DACA51) NEW YORK NY 10278-0090		CODE <div style="text-align: center;">DACA51</div>		7. ADMINISTERED BY (If other than item 6) <div style="text-align: center; font-weight: bold;">See Item 6</div>			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. <div style="text-align: center;">DACA51-02-R-0017</div>	
				X		9B. DATED (SEE ITEM 11) <div style="text-align: center;">03-Jul-2002</div>	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment 0004 to solicitation number DACA51-02-R-0017, is to change some specifications, change the project completion date from 900 calendar days after the Notice to Proceed (NTP) to 700 calendar days after NTP, answer questions of general interest to offerors, and to extend the due date for receipt of pricing proposals. NOTE: Offerors must acknowledge receipt of this amendment by the date specified in the solicitation (or as amended) by one of the following methods: in the space provided on the SF 1442, by separate letter, or by telegram, or by signing block 15 below. FAILURE TO ACKNOWLEDGE AMENDMENTS BY THE DATE AND TIME SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER IN ACCORDANCE WITH THE LATE OFFER, LATE MODIFICATIONS OF OFFERS, OR LATE WITHDRAWAL OF OFFERS (FAR 14.304). As a result of this modification, the pricing proposal (Volume III) due date changes from 23 August 2002 to 29 August 2002, 1400 hours local time.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED <div style="text-align: center;">21-Aug-2002</div>	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION 00010 - SOLICITATION CONTRACT FORM

The required response date/time has changed from 23-Aug-2002 01:00 PM to 29-Aug-2002 02:00 PM.

The contractor period of performance end date has decreased by 365 days from 1095 days to 730 days.

Section 00010 - Solicitation Contract Form

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001	BASE OFFER	1	Lump Sum		
	All work for the C-17 Maintenance Hangar and Aircraft Maintenance Shops as described in the plans and specifications, including all plant and labor, complete and excluding items below.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0002	Site work	1	Lump Sum		
	all work outside the five-foot line of the building perimeter.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0003		1	Lump Sum		
	All design services excluding design services for optional bid items.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0004	Pre-Price Line Item	1	Lump Sum		\$25,000.00
	All work for the Final Record Drawing Submission (See paragraph 10 of Section 0800).				

TOTAL BASE BID (ITEMS 0001-0004): \$_____

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0005	OPTIONAL BID ITEM NO. 1	1	Lump Sum		
OPTION	Additional work for the inclusion of the Canopy on the west side of the Hangar.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0006	OPTIONAL BID ITEM NO. 2	1	Lump Sum		
OPTION	Additional work for the inclusion of the POV Parking Lot and associated access road, sidewalk, and area lighting .				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0007	OPTIONAL BID ITEM NO. 3	1	Lump Sum		
OPTION	Additional work for the inclusion of the Landscaping and associated irrigation.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0008	OPTIONAL BID ITEM NO. 4	1	Lump Sum		
OPTION	Additional work for the inclusion of the Lockers.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0009	OPTIONAL BID ITEM NO. 5	1	Lump Sum		
OPTION	Additional work for the inclusion of the Light Reflective Dry Shake Quartz Floor Hardener in Hangar Bay 114, Wheel and Tire Shop 135, Repair and Reclamation Shop 139, Pneudraulics Shop 141, Sheet Metal shop 156, Corrosion Control/composite Shop 159, and Machine Shop 168.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0010	OPTIONAL OFFER	1	Lump Sum		
	ITEM No. 6				
OPTION	Additional work for the inclusion of the Insulated Translucent Fiberglass Sandwich Panels on the North Face of the High Bay exterior walls.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0011	OPTIONAL BID ITEM	1	Lump Sum		
	NO. 7				
OPTION	Additional work for the inclusion of the Insulated Translucent Fiberglass Sandwich Panels on the East and West Faces of the High Bay exterior walls.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0012	OPTIONAL BID ITEM	1	Lump Sum		
	NO. 8				
OPTION	Additional work for the inclusion of the Standby Power Generator.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0013		1	Lump Sum		
OPTION	OPTIONAL BID ITEM NO. 9				
	FFP				
	Additional work for the inclusion of the Bridge Cranes.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0014	OPTIONAL BID ITEM NO. 10	1	Lump Sum		
OPTION	Addrtional work for the addition of a wood shadow-box type construction fence in lieu of a chain-link construction fence, and to paint the dumpsters, trash containers and temporary sanitation facilities, and contractor trailers, offices and storage buildings, the standard Base colors.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0015	OPTIONAL BID ITEM NO. 11	1	Lump Sum		
OPTION	Deduct price for designing and building the project in English inch-pound (I-P) units in lieu of International System of Units (SI) as shown on the Contract Documents.				

TOTAL OPTION BID ITEMS (0005-0015): \$ _____

TOTAL BASE BID WITH OPTIONAL ITEMS (0001-0015): \$ _____

SECTION 00800 - SPECIAL CONTRACT REQUIREMENTS

The following have been added by full text:

A0004 CHANGES

AMENDMENT #4 TO SPECIFICATIONS FOR FY 02 C17 MAINTENANCE HANGAR AND AIRCRAFT MAINTENANCE SHOPS, McGuire AFB, New Jersey – DACA51-02-R-0017

TO OFFERORS

The following **CHANGES** shall be made to the specifications.

SPECIFICATIONS

Standard Form 1442, Solicitation, Offer and Award

Paragraph 11: **CHANGE** "900" to "730".

Section 00800, Special Contract Requirements

Paragraph 1.a (iii) Change “complete the entire work ready for use not later than 900 calendar days after the date the contractor receives the notice proceed to “complete the entire work ready for use not later than 730 calendar days after the date the contractor receives the notice proceed,”

Section 01012, Design After Award

Paragraph 3.1; **DELETE** paragraph 3.1 in its entirety from this section without replacement.

Paragraph 3.1.1; **DELETE** paragraph 3.1.1 in its entirety from this section without replacement.

Paragraph 4.1; **DELETE** 10% review submittal requirement listing in its entirety from “ Contract Deliverables & Distribution chart.

BIDDER'S QUESTIONS AND GOVERNMENT REPLY

(Questions that may be of general interest of all bidders/Government and that are not readily answered by the proceeding changes will appear below. These questions may have been paraphrased or altered to represent several questions regarding the same subject and/or clarify and simplify the question(s). Questions and answers are issued to the Offerors/Bidders for information only.)

1. **ROOF:** Is it an acceptable alternative to use a caulked liner panel as the vapor barrier, install a system of hats and chairs and fill the cavity with 6" of un-faced metal building fiberglass insulation and then install the outer sheet.

Answer: It is the responsibility of the Offeror to meet or exceed the minimum requirements of the RFP. Based on the limited information provided in this question, it is the opinion of the Government that this system would not be considered equal to the roof system defined in the RFP.

2. **WALL:** No specific questions were contained in this section, only assumptions. In general, the Offeror must comply with requirements of the of the RFP.

The composite wall panel is similar constructed but of aluminum construction.

Answer: This is incorrect. The composite wall panel is 6 mm thick consisting of aluminum sheets between a polyethylene core with associated structural framing. Refer to Specification Section 07414.

The double skin translucent panels can be constructed utilizing an outer sheet fastened to the exterior face of girts and a second sheet fastened to the inner face of girts providing an overall minimum R Value of 2.

Answer: This is incorrect. The translucent panel will be manufactured as a unit and shop fabricated. Field construction is not acceptable.

3. **GENERAL:** Is there any locations in the specifications that actually specify a gauge thickness or is that the responsibility of the manufacturer

whereby the chosen gauge will be based on adherence to the cladding performance specifications.

Answer: Question is not specific. Assume this question applies to both roofing and wall components. The Offeror is responsible for full compliance with all requirements of the RFP. These are considered the minimum acceptable. For the metal roofing system, refer to Specification Section 07412A for minimum design requirements for this system as well as minimum gauges. Composite panels are defined in Specification Section 07414 with minimum gauges. The insulated translucent fiberglass sandwich panel wall system must meet, as a minimum, Specification Section 08900. Wall panels will meet in general the requirements of Specification Section 07413A. Gauges for the metal panel system are dependent on the final design prepared by the Offeror.

r

(End of Summary of Changes)